

RESTAURANT TAFELZIMMER at the Novapark Airplane Hotel

CONTACT	2
GENERAL INFORMATION	2
ACCESSIBILITY	2
Accessibility by public transport	2
CAR PARK	3
PATHS OUTSIDE AND ACCESS	3
Stair lift	4
ENTRANCE	4
RESTAURANT AND BAR	4
GENERAL ACCESSIBLE TOILET	5
Door	5
WC	6
Washbasin	6
Other	6



CONTACT

RESTAURANT TAFELZIMMER at the Novapark Airplane Hotel

Fischeraustraße 22
8051 Graz
T +43 316 68 20 100
office@novapark.at
<https://www.novapark.at>

GENERAL INFORMATION

The Tafelzimmer restaurant is located in the Novapark Flugzeughotel in the north of Graz. It is easily accessible by public transport and also has its own covered parking spaces directly in front of the building.

There are steps leading to the entrance. Wheelchair users can use the stair lift. The stair lift works with the Eurokey.

The Tafelzimmer restaurant offers a variety of Styrian delicacies and delicious international dishes. From Monday to Friday, it offers a lunch buffet that is also open to non-residents. Reservations are requested.

Outside opening hours, the Tafelzimmer restaurant can be booked for events and celebrations. The breakfast buffet and piano bar are also available daily.

The restaurant in the aeroplane on the roof of the hotel is not wheelchair accessible, but the bar in the second aeroplane can be reached via the lift and the terrace.

ACCESSIBILITY

Accessibility by public transport

Please use the route planner of the Verbundlinie Steiermark:
<https://verkehrsauskunft.verbundlinie.at>

CAR PARK

- There is at least one accessible parking space in the hotel's own car park.
- It is located near the accessible entrance, on a level surface
- with clearly visible floor markings, **no signposting**
- The parking space is perpendicular or at an angle to the road, at least 350 cm wide and covered.
- The barriers do not open automatically, but can be operated from the car.
- **Barriers not secured against being walked under with a white cane**
- Contrasting colour markings on the parking space boundaries (the corners are marked).
- On level ground, flooring is easy to drive on with a wheelchair and low-vibration (asphalt)
- **No emergency call system available**



Parking space

PATHS OUTSIDE AND ACCESS

- Access to the hotel is threshold-free, at least 150 cm wide, completely level
- Path easy to navigate and low-vibration, free of obstacles
- **Path not covered, not continuously lit**
- **Pavement edges not easily detectable with a white cane**
- Clear height under signs is at least 220 cm
- **No tactile floor guidelines to the entrance**
- There are several steps leading to the entrance, which can be overcome with a stair lift



Entrance with stair lift



Entrance with stair lift

Stair lift

- Level access, lockable with Eurokey!
- At the entrance, there is a manoeuvring area of at least 120 x 120 cm; **at the exit at the top, the length is only 96 cm**
- Controls at standard height
- Help can be obtained by calling reception
- Wheel deflectors available
- Minimum rated load is specified
- Platform dimensions at least 80 cm wide x 90 cm deep, but smaller than 80 x 100 cm

ENTRANCE

- The main entrance is the barrier-free entrance (easy to find)
- Entrance covered, free of obstacles
- Clear width of the entrance door at least 90 cm, no door threshold
- Vestibule: two automated sliding glass doors, open early and close with a time delay
- **Glass doors not marked with contrasting markings**
- Door opening side marked
- **Door opening button at a height of 100 cm** (standard max. 85 cm)
- Movement area on both sides of the doors at least 150 cm long x 120 cm wide
- Grating or dirt-trapping mat easily passable

RESTAURANT AND BAR

- Accessible without thresholds
- Barrier-free WC nearby
- Passage widths of main corridors at least 100 cm, of cross corridors at least 70 cm
- **Counter higher than 85 cm, no wheelchair access**
- Tables are wheelchair accessible (at least 80 cm wide, 70 cm high, 60 cm deep), table height max. 85 cm
- High chairs for children available
- Seating 46–50 cm high, with sturdy armrests and backrests
- Tables with glare-free lighting are also available in the breakfast room
- buffet without service
- Clear width of the path next to the buffet at least 120 cm
- Food is within reach at 40–70 cm, food selection at 85 cm height
- Straws can be provided
- Restaurant and bar are free of dust-prone carpets and upholstered furniture, **but there are curtains**
- Options available for people with food allergies
- Staff are aware of the ingredients in the food, but are not specially trained



Restaurant and bar

GENERAL ACCESSIBLE TOILET

- Separately located (unisex)
- Movement area of 150 x 150 cm is available in the toilet room

Door

- Sliding door, clear door width at least 80 cm, no door threshold
- Easy to open, can be unlocked from the outside in an emergency
- Door handle at standard height, no twist, knob or shell handle
- Door handle stands out in contrast to adjacent components
- Approach area on the opening side at least 200 x 150 cm, **on the closing side 82 x 120 cm** (standard at least 150 x 120 cm)
- On the opening side of the door, there is a side approach area of at least 50 cm next to the door handle; **on the closing side, there isn't**



General accessible toilet

WC

- At least 120 cm of space in front of the toilet bowl for manoeuvring
- Accessible from the left, with at least 90 cm of space on the side for manoeuvring
- Distance between the front edge of the WC and the rear wall for manoeuvring: at least 65 cm
- **Toilet height 54 cm** (standard 46–48 cm), **no backrest**
- Horizontal grab rails on both sides, **no additional vertical grab rail**
- Grab rails can be folded up on both sides
- Grab rails at standard height (75–85 cm), distance between grab rails 65–70 cm
- **Grab rails do not protrude at least 15 cm beyond the front edge of the toilet**
- Folded-up grab rails protrude max. 20 cm into the room
- Folding support handles securely attached to the wall, easy to use
- Flush at standard height (80–110 cm), **not accessible from the toilet when seated**
- Toilet paper accessible from a seated position, **but roll not in the folding support handle**
- **No emergency bell available**

Washbasin

- Movement area in front of the washbasin at least 120 x 120 cm, **but less than 150 x 150 cm**
- Top edge of the washbasin at standard height
- **Clear height under the washbasin less than 70 cm**, flat plaster siphon, made of plastic or protected with porcelain
- Depth complies with standard
- Under washbasin wheelchair access over a width of at least 100 cm
- Touchless or single-lever tap, distance to the front edge of the washbasin max. 20–35 cm

Other

- **Lower edge of mirror at a height of 113 cm** (standard max. 95 cm)
- Operating level of fittings at a height of 80–110 cm
- Waste bin can also be operated with one hand
- **Fittings do not stand out visually from their surroundings**

As of December 2025, all information provided without guarantee

Photos: Graz Tourismus – Harry Schiffer, Ikarus

Source: http://www.bereit-fuer-barrierefreiheit.eu/de/Betriebe/?xt=CEDOSCheckResults&xtMethod=showDataset&cat_id=1641&tobj_id=3189